

Dated :- 28/03/2025

## Annexure C

### Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Lakbbir Singh, SI  
(Name of Officers with designation) from O/c Civil Surgeon Ropar  
(Name of Department/ Office) inspected the Neta ji Model School, Mangobind Nagar, Ropar.  
(Name & Address of the school) on 12/03/2025 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
The above is valid for a period of 1 year....

Signature with Seal: .....

Name \_\_\_\_\_

Designation :

Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name &amp; Address of the Office / Department : ...

To

Netaji Model School  
Hargobind Nagar, Roopar.

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

# DISTRICT WATER TESTING LABORATORY, ROOPNAGAR

Department of Water Supply and Sanitation, Division -2 , Roopnagar  
dwtlrpr@gmail.com

## TEST REPORT


|   |   |                          |  |
|---|---|--------------------------|--|
| Name & Address of Customer :<br><b>Netaji Model School, Hargobind Nagar</b><br><b>Netaji Model School, Hargobind Nagar, Roopnagar</b> |   | Customer Reference No.   | No : Letter No. 20110/NJMS/302/DW/F25 Dated : 12/03/2025         |
|   |   | Sample Submitted by      | Bharati Saini  |
|   |   | Date of Sample Receipt   | 12/03/2025   |
|   |   | Analysis Starting Date   | 20/03/2025   |
|   |   | Analysis completion Date | 25/03/2025   |
| Discipline : <b>Chemical Testing</b>  |   | Group: <b>Water</b>      |  |
| ULR No.:  | TC98822500000098F                                       | Sample Type :            | Water  |
| Test Report No.:  | DWTLRPR/2425/00415                                      | Date of Issue :          | 25/03/2025   |
| Registration no.:   | DWTLRPR/REG2425/00932                                   | Condition of Sample :    | Unsealed   |
| Collection Point:   | Distribution Point(Near Bus stand,School,Gurudwara,etc) | Quantity/Type of Bottle: | 1000 ml / HDPE Bottle  |
| Scheme/Source:  | Not Mentioned(Not Mentioned)                            | Location/Depth :         | Netaji Model School, Hargobind Nagar, Roopnagar (TAP WATER) / NA |
| Village :   | Not Mentioned   | Habitation :             | Not Mentioned  |
| Block:  | Not Mentioned   | District :               | Roopnagar  |
| Latitude :  | Not Mentioned   | Longitude:               | Not Mentioned  |

| Sr. No | Parameter                      | Result    | As per IS-10500:2012 (2nd Rev.) |                   | Unit | Reference Method :  |
|--------|--------------------------------|-----------|---------------------------------|-------------------|------|---|
|        |                                |           | Acceptable Limit                | Permissible Limit |      |   |
| 1      | pH                             | 6.85@25°C | 6.5-8.5                         | No Relaxation     | --   | IS 3025 (Part 11-2022) Electrometric Method                   |
| 2      | Colour                         | <5        | 5                               | 15                | CU   | IS 3025(Part 4-2021) Visual Comparison Method                 |
| 3      | Odour                          | Agreeable | Agreeable                       | Agreeable         | --   | IS 3025 (Part 5 – 2018) (Second Revision)                     |
| 4      | Taste                          | NT        | Agreeable                       | Agreeable         | --   | IS 3025 (Part 8 – 2023)                                       |
| 5      | TDS                            | 195       | 500                             | 2000              | mg/l | IS 3025 (Part 16-2023) Gravimetric Method                     |
| 6      | Turbidity                      | 1.81      | 1                               | 5                 | NTU  | IS 3025 (Part 10-2023) Nephelometric Method                   |
| 7      | Alkalinity(CaCO <sub>3</sub> ) | 172       | 200                             | 600               | mg/l | IS 3025 (Part 23-2023) Indicator Method                       |
| 8      | Hardness(CaCO <sub>3</sub> )   | 112       | 200                             | 600               | mg/l | IS 3025 (Part 21- 2009)(RA 2023) EDTA Method                  |
| 9      | Calcium(Ca)                    | 19.24     | 75                              | 200               | mg/l | IS 3025 (Part 40-2024) EDTA Titrimetric Method                |
| 10     | Magnesium(Mg)                  | 15.55     | 30                              | 100               | mg/l | APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method |
| 11     | Chloride(Cl)                   | 11        | 250                             | 1000              | mg/l | IS 3025 (Part 32-1988) Argentometric Method                   |

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Praveen Singh Danu  
Chemist/Analyst  
Authorized Signatory  
For, District Water Testing Laboratory  
Roopnagar

End of the Test Report



**DISTRICT WATER TESTING LABORATORY, ROOPNAGAR**  
Department of Water Supply and Sanitation, Division -2 , Roopnagar  
dwtlpr@gmail.com

**Payment Receipt**

**Receipt No. : 22908**

**Date : 19/03/2025**

**Invoice No. : INV/2425/00382**

**Invoice Date : 19/03/2025**

**Received From :** Netaji Model School, Hargobind Nagar  
Netaji Model School, Hargobind Nagar, Roopnagar

**The Sum of Rupees :** One Hundred Thirty Only.

**In** Cash

**Rs. : 130.00**

Disclaimer: -Payment made by cheque/online mode are subject to clearance by bank.

*Harpreet Singh*

**For** District Water Testing Laboratory, Roopnagar  
Authorized Signatory

**DISTRICT WATER TESTING LABORATORY, ROOPNAGAR**

Department of Water Supply and Sanitation, Division -2 , Roopnagar  
dwtlrpr@gmail.com

To,

Netaji Model School, Hargobind Nagar  
Netaji Model School, Hargobind Nagar, Roopnagar


No.: DWTLRPR/2425/00415      Dated : 25/03/2025

Subject :      Testing Reports of Water Samples.

Reference:      Your Letter/SRF No. Letter No. 20110/NJMS/302/DW/F25      Dated: 12/03/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 12/03/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Roopnagar

D/A :      Test Report



**Authorized Signatory  
For, District Water Testing Laboratory  
Roopnagar**